

## 16 SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Designation of consumer unit:

**D.B. 1 wylex**

Location:

Garage

Prospective fault current:

0.78 kA

Type of Wiring  
O-Other:

N/A

[illegible]

## 17 TEST INSTRUMENTS

Multi-functional:

8046791

Insulation resistance:

N/A

Continuity:

N/A

Earth electrode resistance:

N/A

Earth fault loop impedance:

N/A

RCD:

N/A