



## **Certificate of Design, Installation and Commissioning of a Smoke/Heat Alarm System to Grade D, E or F as defined in BS 5839-6: 2013**

Certificate of design, installation and commissioning\* of fire detection and fire alarm system at:

Address:.....

.....

.....

It is certified that the fire detection and fire alarm system at the above address complies with the recommendations of BS 5839-6: 2013 for design, installation and commissioning of a Category....., Grade..... system, other than in respect of the following variations:\*

.....

.....

Brief description of areas protected (only applicable to Category LD2 systems):

.....

.....

The entire system has been tested for satisfactory operation in accordance with the recommendations of **23.3p)** of BS 5839-6: 2013\*.

*The requirements of paragraph p) section i) of Clause 23.3 have not been performed, having been substituted by following the Inspection and Testing Procedure recommendations contained within the Siting and Installation Instructions supplied by the manufacturer of the smoke/heat alarms installed*

Instructions in accordance with the recommendations of Clause **24** of BS 5839-6: 2013 have been supplied to:\*

Signed..... Date.....

For and on the behalf of.....

**\*Where design, installation and commissioning are not all the responsibility of a single organisation or person, the relevant words should be deleted. The signatory of the certificate should sign only as confirmation that the work for which they have been responsible complies with the relevant recommendations of BS 5839-6: 2013. A separate certificate(s) should then be issued for other work.**

This certificate may be required by an authority responsible for enforcement of fire safety legislation, such as the building control authority or housing authority. The recipient of this certificate might rely on the certificate as evidence of compliance with legislation. Liability could arise on the part of any organisation or person that issues a certificate without due care in ensuring its validity.