



**LEGEND**

- [Symbol] DISTRIBUTION BOARD/CONSUMER UNIT
- [Symbol] SPLIT METERED DISTRIBUTION BOARD
- [Symbol] PROTECTIVE DEVICE (MCCB)
- [Symbol] PROTECTIVE DEVICE (FUSE SWITCH)
- [Symbol] 2-POLE ISOLATOR (80A)
- [Symbol] HENLEY RED HEAD SERIES FUSE (80A)
- [Symbol] FUSE SWITCH DISCONNECTOR
- [Symbol] CT CHAMBER & UTILITY METER
- [Symbol] MULTIFUNCTION METER
- [Symbol] APARTMENT UTILITY METER
- [Symbol] SPD
- [Symbol] UNSWITCHED FUSE CONNECTION UNIT
- [Symbol] SWITCHED FUSE CONNECTION UNIT
- [Symbol] DOUBLE POLE KEY OPERATED SWITCH ENGRAVE WITH: "FIRE ALARM - DO NOT SWITCH OFF" - FOR FAP/VESDA "EMERGENCY VOICE COMMUNICATION - DO NOT SWITCH OFF" - FOR EVC
- [Symbol] SP&N ISOLATOR
- [Symbol] TP&N ISOLATOR
- [Symbol] INTEGRAL EARTH BAR WITHIN BOARD
- [Symbol] E EARTH BONDING CONDUCTOR

**PROTECTIVE DEVICE LEGEND**

FRAME SIZE	FUSE RATING	DEVICE TYPE
-	-	-
-	-	-
-	-	-

SP&N/TP&N

- NOTES**
- DO NOT SCALE FROM THIS DRAWING
  - DRAWING TO BE READ IN CONJUNCTION WITH SPECIFICATION, DOCUMENTATION, DRAWINGS & ALL RELEVANT BRITISH STANDARD DOCUMENTS
  - ALL ELECTRICAL WORKS SHALL COMPLY WITH 18TH EDITION IET WIRING REGS BS7671:2018 (2018), INCLUDING ALL CURRENT MENDMENTS AND GUIDANCE NOTES AND THE CURRENT BUILDING STANDARDS REGULATIONS
  - THE INSTALLATION SHALL ONLY BE CERTIFIED BY A PERSON OR A COMPANY HAVING MEMBERSHIP TO S.E.I.E.C.T. OR N.I.C.E.I.C. OR SIMILAR ELECTRICAL SCHEMES

DRG STATUS **PRELIMINARY**

CLIENT

PROJECT

DRG TITLE  
**LV SCHEMATIC**

DRG No. **SACT-JSM-A1-XX-DR-E-6001**

CHECKED BY	REVISION  P02	SCALE  NTS@A1	
		DRAWN	DATE 28JUNE2